



Product Service

EU-Type Examination Certificate

No. C5A 022629 0038 Rev. 01

Holder of Certificate: **Karl Dungs GmbH & Co. KG**

Karl-Dungs-Platz 1
73660 Urbach
GERMANY

Product:

Fittings (Gas)

Closed position indicator switch

K01/1

PIN CE-0123DL1023

The Certification Body of TÜV SÜD Product Service GmbH confirms according to Annex III (Module B) that the listed product complies with the relevant provisions according to Annex I of Regulation (EU) 2016/426 on appliances burning gaseous fuels. It refers only to the sample submitted for testing and certification and on its technical documentation. For details see: www.tuvsud.com/ps-cert

Test report no.: V 1660-01/21

Valid until: 2030-09-10

Date, 2021-08-09

(Klaus Joachim Kurth)



EU-Type Examination Certificate

No. C5A 022629 0038 Rev. 01

Model(s): K01/1

Models

K01/1 „IP 54“; K01/1 „IP 65“

Technical data / range of application

gas family	all gases of 1 st , 2 nd and 3 rd gas family
max. operating pressure	500 mbar / 50 kPa
ambient temperature	-15°C to +70°C
rated voltage	AC 250 V
contact load	max. 5 A, cos φ= 1
degree of protection	IP 54 resp. IP 65 (see models)
installation position	push rod in vertical to horizontal position

Further details

Furthermore, the closed position indicator switch fulfills the requirements of ISO 23551-1:2012 together with ISO 23550:2011 including the specific regional requirements in European countries according to Annex E.

Tested according to: DIN EN 161:2013
DIN EN 13611:2019

EU-Baumusterprüfbescheinigung

Nr. C5A 022629 0038 Rev. 01

Zertifikatsinhaber: **Karl Dungs GmbH & Co. KG**
Karl-Dungs-Platz 1
73660 Urbach
DEUTSCHLAND

Produkt: **Ausrüstungen (Gas)**
Meldeschalter

K01/1

PIN CE-0123DL1023

Die Zertifizierstelle von TÜV SÜD Product Service GmbH bestätigt gemäß Anhang III (Modul B) die Übereinstimmung des bezeichneten Produktes mit den wesentlichen Anforderungen gemäß Anhang I der Verordnung (EU) 2016/426 über Geräte zur Verbrennung gasförmiger Brennstoffe. Prüfgrundlage ist ausschließlich das zur Prüfung und Zertifizierung vorgestellte Prüfmuster sowie dessen technische Dokumentation. Details siehe bitte: www.tuvsud.com/ps-zert

Prüfbericht Nr.: V 1660-01/21

Gültig bis: 2030-09-10

Datum, 2021-08-09



(Klaus Joachim Kurth)

EU-Baumusterprüfbescheinigung

Nr. C5A 022629 0038 Rev. 01

Modell(e): K01/1

Ausführungen

K01/1 „IP 54“; K01/1 „IP 65“

Technische Daten / Verwendungsbereich

Gasfamilie	alle Gase der 1., 2. und 3. Gasfamilie
Max. Betriebsdruck	500 mbar / 50 kPa
Umgebungstemperatur	-15°C bis +70°C
Bemessungsspannung	AC 250 V
Kontaktbelastung	max. 5 A, $\cos \varphi = 1$
Schutzgrad	IP 54 bzw. IP 65 (je nach Ausführung)
Einbaueinlage	Schubstange senkrecht stehend bis waagrecht liegend

Weitere Angaben

Der Meldeschalter erfüllt auch die Anforderungen der ISO 23551-1:2012 in Verbindung mit ISO 23550:2011 einschließlich der spezifischen regionalen Anforderungen in Europäischen Ländern gemäß Anhang E.

Geprüft nach: DIN EN 161:2013
DIN EN 13611:2019